



STATE OF WASHINGTON
DEPARTMENT OF HEALTH

OFFICE of ENVIRONMENTAL HEALTH and SAFETY

243 Israel Road SE • PO Box 47824 • Olympia, Washington 98504-7824
(360) 236-3330 • TDD Relay Services 1-800-525-0127

February 23, 2016

Dick Bachelder
Infiltrator Systems Inc.
PO Box 768
Old Saybrook, CT 06475

**Re: Addition of NuWater BNR-600 Treatment Units as an Approved Usage for
Infiltrator Systems Inc. Sewage Tank Model IM-1060**

Dear Mr. Bachelder:

Your request dated February 19, 2016, to add NuWater BNR-600 treatment units to the usage of the Infiltrator Systems Inc. Tank Model IM-1060 is **approved**.

We will include this additional usage, as shown on the enclosed table, with the next update of the *List of Registered Sewage Tanks* (List). We typically update the List quarterly. This letter will serve as your approval until the next update.

If you have any questions, please contact me at (360) 236-3360 or by email at jeanne.andreasson@doh.wa.gov.

Sincerely,

Jeanne Andreasson, P.E.
Environmental Engineer
Large On-Site Systems

Enclosure

cc: Nathan Ek, NuWater
Brad Routh, Infiltrator Systems, Inc.
Laura Homan, Compliance Manager, DOH
Leslie Turner, Wastewater Specialist, DOH

Manufacturer	Model Number	Tank Size (gallons)	Number of Compartment	Usage	Date Approved	Limitations
Infiltrator Systems Inc. PO Box 768 4 Business Park Rd Old Saybrook, CT 06475 1-800-221-4436 860-577-7793 (fax) www.infiltratorsystems.com dlentz@infiltratorsystems.net Tank Material: Polyethylene Polypropylene	IM-1060	1070	One/Two	Septic Tank, Pump Tank, Holding Tank, Trash Tank, MicroFast Treatment Units, and NuWater BNR-600 Treatment Units	1-23-2014 / 12-31-2016	Anti-buoyancy measures required if <12" soil cover over tank and water table has the potential to rise 30" or more above bottom of tank. The tank shall not be installed where the water level outside the tank exceeds the height of the outlet pipe saddle. 4' maximum depth of burial